

IN THE EVENT OF A GAS ESCAPE OR SMELL OF FUMES

Instruction to Responsible Premises Officer

Instruction to Tenant

If gas or fumes escaping

If gas or fumes escaping

- Turn the gas supply off at the meter/emergency control valve to prevent further escape of gas or fumes and to ventilate the property. Do not smoke, light a fire, use electrical appliances or turn on switches until problem is fixed

- Turn the gas supply off at the meter/emergency control valve to prevent further escape of gas or fumes and to ventilate the property. Do not smoke, light a fire, use electrical appliances or turn on switches until problem is fixed

If gas/fumes continue to escape

If gas/fumes continue to escape instruct the Tenant to immediately

- Call the National Gas Emergency Service Call Centre, on telephone number

0800 111 999

and take a note of the job number given

- In the case of Liquefied Petroleum Gas (LPG), contact the gas supplier on

.....
(RPO to insert relevant number here)

- The gas supply must not be used until remedial action has been taken to correct the defect and the installation has been re-commissioned by a competent person

- Call the National Gas Emergency Service Call Centre, on telephone number

0800 111 999

and take a note of the job number given

- In the case of Liquefied Petroleum Gas (LPG), contact the gas supplier on

.....
.....
.....
.....
.....

(some typical suppliers and contact nos may be noted here)

- The gas supply must not be used until remedial action has been taken to correct the defect and the installation has been re-commissioned by a competent person

The above as an abstract from and further information is available in Section 4 (OI-ISC-008 and 008.1) of this Document

The above as an abstract from and further information is available in Section 4 (OI-ISC-008 and 008.1) of this Document