

The Highland Council: Scheduled Watercourse Maintenance Works - Pending

Works Number	Watercourse Name	Location	Date for Re-Inspection*	Description of Works
1	Eil Burn	Station Road beside "Eilburn"	20/11/2015	Remove debris and clear culvert inlet.
204	Craggan Mill Burn	A95 at Craggan Mill, Grantown-on-Spey	09/06/2015	Vegetation and silt build up at culvert inlet/outlet and through culvert to be removed as it is causing a partial blockage and potential flood risk. BEAR informed of works required.
216	Rhives Burn	Ben Braggie car park	30/03/2015	Remove debris and repair the collapsed culvert in the Ben Braggie car park. Landowner contacted and asked to carry out works.
222	Ussie Burn	Behind Cottage Bar, Maryburgh	27/11/2015	Branches and debris causing a partial blockage in the burn. Land ownership uncertain
224	Blair of Tarradale Burn	A832 200m west of B9169 junction	15/04/2016	Debris and vegetation to be cleared from culvert inlet.
227	Gillibrath Drain	Railway by A830/B8006 junction, Corpach	10/11/2015	Culvert and watercourse leading to culvert to be cleared of vegetation and silt/debris build up. Network Rail informed of works required.
267	Macrae Grove Burn	To the rear of 12 Macrae Grove	14/07/2015	Ditch at culvert inlet is overgrown causing partial blockage of the screen. Area immediately upstream of screen to be cut back and dead vegetation removed. Landowner contacted and asked to carry out works.
284	Mill Burn	Opposite 35 Harris Road	22/03/2016	Scottish Water sewer outfall headwall is partially collapsed into the watercourse. Headwall to be repaired. Scottish Water informed of works required.
296	Kinellan Burn	Adjacent to A834, upstream of St Anne's Episcopal Church	28/11/2015	New screen arrangement to be designed and installed at culvert inlet to replace existing damaged screen.
330	Ault na Skiah	Upper Slackbuie	29/06/2015	Woody debris to be removed from screen which is 80% blinded. Gravel deposits to be cleared from upstream side of screen also.
332	Pitmain Burn	A86, Kingussie	26/07/2015	Culvert inlet and outlet partially blocked with sediment and cobbles. BEAR informed of works required
343	Eil Burn	Conon Bridge	06/08/2015	Clear watercourse of sediment and debris for 10m upstream of screen
354	Lochalsh Burn 5	Kyle of Lochalsh	15/07/2015	Footbridge Culvert has partially collapsed restricting flow in the burn and causing overtopping upstream. Land ownership uncertain.
355	Fairburn Well	Marybank	30/08/2015	Poor conveyance through culvert due to sediment build up. Clear sediment immediately upstream of culvert and jet.
367	SWFRC	Essich Road	29/06/2015	Trash screen partially blinded. Clear and remove material from site.
370	Kirkhill Burn	Wardlaw Road, Kirkhill	30/08/2015	Debris requiring removal from parts of the watercourse that act as roadside verge
373	Tower Burn	Cranmore Drive	10/06/2015	Suspected debris from tree clearance work left in burn causing blockage risk. Remove from Burn. Passed to SSE.
383	Brown Terrace Burn	Kinlochleven	09/08/2015	Rocky debris and sediment building up at the culvert outfall. Clear a 10m section to hard (constructed) bed level from the culvert outlet.
385	Auldearn Burn	Newmill	18/06/2015	Sediment buildup in front of bridge causing a restriction to flow. Remove from watercourse.
388	Druid Temple Burn	Drakies Playing Field, Grebe Avenue.	24/06/2015	Fallen tree lying within the watercourse causing a partial blockage. Remove tree and trapped debris from the watercourse.
394	River Peffery	Between Tulloch Street and railway bridge	12/07/2015	Uprooted trees washed up on bank. Cut into smaller sections to allow them to pass downstream without snagging
395	Essich Burn	Torbreck/Ness Castle	29/09/2015	Stones and rubble blocking one inlet to a double culvert. Landowner contacted and requested to remove blockage.
398	Pine Grove Burn	Culvert inlet at the Playground	27/06/2015	Remove concrete blocks and debris from the inlet area, re-secure the screen to the hasp, ensure water can flow freely from the culvert inlet either by rodding or jetting.
399	Tain Burn 2	Behind Rowan Drive and Hawthorn Way	25/08/2015	Area Team to remove all debris from the length of the between St Vincent and the Inlet of Structure 60.
402	Dell Burn	Raigmore Park, A9 Culverts	30/08/2015	Trash screen partially blinded. Clear and remove material from site.

* The stated date for re-inspection denotes when the re-inspection is due and not when the works are due to be carried out