

The Highland Council: Scheduled Watercourse Maintenance Works - Complete April/May 2017

Works Number	Watercourse Name	Location	Date Works Carried Out	Description of Works
504	Balantoul Burn	A82, Fort Augustus	13/04/2017	Clearance of sediment and vegetation from in front of flap valves and screen.
505	Alma Burn	Belford Road, Fort William	03/05/2017	Buried manhole needs to be uncovered and sections of culvert to be cleared of debris/silt.
506	Glasdrum Burn	High Street, Police Station, Fort William	03/05/2017	Buried manholes need to be uncovered and section of culvert to be cleared of stones and leaves.
507	Whin Burn	Lundavra Road and A82 roundabout, Fort William	03/05/2017	Section of culvert needs to be cleared of debris which was detected during CCTV Survey.
508	Iona Burn	Lundavra Road and Argyll Terrace, Fort William	03/05/2017	Sections of culvert to be cleared of high volume of debris/stones as identified during CCTV Survey.
509	Ashburn	Junction of Lochaber Road and Zetland Avenue, Fort William	09/05/2017	Fixings of inlet screen to be replaced with new fixings. Leaves and branches sitting behind the screen to be cleared.
510	Allt Achan a Clath Trib 1	Selkirk Place, Fort William	03/05/2017	Section of culvert to be cleared of stones.
517	Dingwall Flood Defences	Behind Obriens workshop and yard Docharty Industrial estate	23/05/2017	Clear debris and vegetation from the flap valve to ensure valve operates freely, clear ditch downstream for 10m.
519	Culloden Burn West	Culloden Park	21/04/2017	Remove two large tree branches cast aside from the burn
520	Culloden Burn West	Behind Culloden Centre	21/04/2017	Remove debris from the screen below lower landing
521	Culloden Burn South	Outlet of culvert between Barn Church Road and Ferntower Road.	16/05/2017	Remove all debris cast aside from the outlet of the culvert, clear burn invert to a point 10m downstream from the outlet to ensure free water flow from the outlet. Removal of debris off site.
522	Slackbuie Channel	Watercourse behind West Heather Road	16/05/2017	Remove large woody items from the channel
524	Ashburn	Near to the old Upper Achintore Primary School	31/05/2017	Repair sidewall which has started to collapse into the blockwork channel, remove the small self seeded trees which are growing in the same area as the collapse.
525	Ashburn	Between Moray Place and Caithness Place	31/05/2017	Clear the inlet area of silt and grassy deposits up to 5m and no more than 10m upstream of the culverts. Remove all vegetation growing out from the sidewalls.