## The Highland Council: Scheduled Watercourse Maintenance Works - Complete October/November 2017

Works Number	Watercourse Name	Location	Date Works Carried Out	Description of Works
534	Not Allocated	Garden Ground Inverkirkaig		Sidewalls of a stone culvert have slipped inwards which has reduced the capacity of the culvert to convey forward water flow, as a result water flow during heavy and prolonged rainfall backs up and floods the lower part of the garden.
535	Not Allocated	Un-named trib of Allt Melvaig	28/10/2017	Urgent removal of a blockage in an un-named tributary of the watercourse Allt Melvaig