

The Highland Council: Scheduled Watercourse Maintenance Works - Pending

Works Number	Watercourse Name	Location	Date for Re-Inspection*	Description of Works
296	Kinellan Burn	Adjacent to A834, upstream of St Anne's Episcopal Church	06/01/2019	New screen arrangement to be designed and installed at culvert inlet to replace existing damaged screen.
354	Lochalsh Burn 5	Kyle of Lochalsh	24/03/2019	Footbridge Culvert has partially collapsed restricting flow in the burn and causing overtopping upstream. Land ownership uncertain.
454	Clachan Burn	Bettyhill	21/08/2018	Build up of gravel and sediment to be removed, vegetation within watercourse to be removed
462	Ault na Skiah	Castle Heather Park by B8082	03/09/2018	Silt trap is full and requires material to be removed.
512	Rainbow Burn	Bruce Gardens, Fortrose	12/12/2018	Sections of culvert to be cleared of roots.
513	Kings Burn	Junction of Lower Wards and E Watergate, Fortrose	12/12/2018	Section of culvert to be cleared of roots.
529	Knightswood Burn	A870 at the junction with Auchingale Place Watten.	22/08/2018	The Invert levels of the ditch have risen due to vegetation and silt deposition. Return ditch to original invert level to help mitigate flooding on to the roads.
532	Lochalsh Burn 4	Church Street, Kyle of Lochalsh	28/12/2018	Replace section of collapsed stone culvert with 400mm diameter pipe.
537	Allt na Laitch	A862 prior to the Mineral Bridge	03/09/2018	Remove all vegetation and silt and stones which have accumulated in front of the screen, clear the culvert outlet to a point 10m downstream this will allow any silt which has accumulated within the culvert to wash out
540	Parks Farm Burn	Outlet of the Parks Farm Burn in to the Druid Temple Burn at the Grebe Avenue Hall	19/10/2018	Secure the chain to the screen which has been removed.
549	Scretan Burn Trib 3	Behind 1 Brinkman Terrace	12/09/2018	The culvert is blocked and requires clearing this is not an urgent job as there is an overflow channel
551	Culduthel Channel	Interface with the SWFRC near Culduthel Mains Circle	21/09/2018	Remove vegetation which is partially blocking the culvert inlet and forcing water to flow into the SWFRC
552	Lochardil Burn	Lodge Park	19/10/2018	Remove all vegetation which is blocking the watercourse in the Lodge Park area.
556	Ashburn	Either side of the footbridge on Campbell Court, Ross Place	21/08/2018	Please removed vegetation which has been dumped into the watercourse on Campbell Court
557	River Peffery Trib 3	Docharty Road Dingwall	21/08/2018	Please remove the tree from the middle of the burn and clear the burn back to the original culvert invert level to a point 10m downstream from the culvert outlet
559	Mill Burn	Harris Road Inverness	19/10/2018	Remove a 10m X 2m area of silt deposition at the outlet of the box culvert which has restricted the width of the burn, remove areas of minor vegetation from the culvert inlet upto the footbridge which is opposite Milton Crescent

\* The stated date for re-inspection denotes when the re-inspection is due and not when the works are due to be carried out