

The Highland Council: Scheduled Watercourse Maintenance Works - Pending

Works Number	Watercourse Name	Location	Date for Re-Inspection*	Description of Works
296	Kinellan Burn	Adjacent to A834, upstream of St Anne's Episcopal Church	18/07/2022	New screen arrangement to be designed and installed at culvert inlet to replace existing damaged screen.
580	South Kessock Seawall	3 Areas in the seawall	06/09/2022	Repair missing stones sets in the seawall
608	Dingwall Flood Defences	Canal footpath At victoria park	06/09/2022	Infill and seal holes in the embankment where rabbits have been burrowing.
611	Dingwall Flood Defences	Canal footpath At victoria park	06/09/2022	Cut back and trim all vegetation growing in and along the flood embankment
624	Whaligoe Burn 1	Junction A99 road to Loch Watenan	15/08/2022	Remove blockage from within the road culvert. BEAR contacted and made aware of works required.
626	Mill Burn	Culvert under Sir Walter Scott Drive	06/09/2022	Remove all silt and stone deposition from the inlet and ditch 10m upstream from the inlet
627	Mill Burn	Harris Road Inverness	06/09/2022	Remove large tree which is lying in and across the burn
628	Druid Temple Burn	Druid Temple Crescent, Inverness	06/09/2022	Remove all silt and stone deposition from the inlet and ditch 10m upstream from the inlet
633	Druid Temple Burn	Next to the playing ground at Grebe Avenue Hall	06/09/2022	Remove all vegetation lying in and across the burn which is restricting forward flow of water
635	Ault na Skiah	Adjacent to the Distributor Road (B8082) behind properties on Castle Heather Avenue	06/09/2022	remove silt accumulations from the culvert inlet which has reduced the culvert width by approx 50%, please remove any self seeded trees that are growing in the burn or on the burn sides.
636	SWFRC	SWRFC numerous locations	06/09/2022	Remove all vegetation gorse/whin are growing on the crown and sides of the flood relief channel. Currently growing in numerous areas
641	Eil Burn	Behind Burnside Lane	02/09/2022	Remove vegetation along ditch. Priority increased following updated observation of increased weed growth.
644	Mill Burn	Behind Millburn Court	06/09/2022	Remove internal blockage within Left hand Culvert, specialist contractor may be required due to the confined space.
651	Dingwall Flood Defences	Sections 3, 4 and 5	24/07/2022	Complete clearance of all vegetation growing in sections 3, 4 and 5 of the flood defences
654	Mill Burn	Harris Road Inverness	06/09/2022	Remove blockage which is lying in and across the burn, removal of tree limb from culvert inlet under Harris Road

* The stated date for re-inspection denotes when the re-inspection is due and not when the works are due to be carried out