

The Highland Council: Scheduled Watercourse Maintenance Works - Pending

Works Number	Watercourse Name	Location	Date for Re-Inspection*	Description of Works
580	South Kessock Seawall	3 Areas in the seawall	27/02/2024	Repair missing stones sets in the seawall
608	Dingwall Flood Defences	Canal footpath At victoria park	02/01/2024	Infill and seal holes in the embankment where rabbits have been burrowing.
611	Dingwall Flood Defences	Canal footpath At victoria park	02/01/2024	Cut back and strim all vegetation growing in and along the flood embankment
626	Mill Burn	Culvert under Sir Walter Scott Drive	10/04/2024	Remove all silt and stone deposition from the inlet and ditch 10m upstream from the inlet
628	Druid Temple Burn	Druid Temple Crescent, Inverness	10/04/2024	Remove all silt and stone deposition from the inlet and ditch 10m upstream from the inlet
633	Druid Temple Burn	Next to the playing ground at Grebe Avenue Hall	10/04/2024	Remove all vegetation lying in and across the burn which is restricting forward flow of water
635	Ault na Skiah	Adjacent to the Distributor Road (B8082) behind properties on Castle Heather Avenue	10/04/2024	remove silt accumulations from the culvert inlet which has reduced the culvert width by approx 50%, please remove any self seeded trees that are growing in the burn or on the burn sides.
636	SWFRC	SWRFC numerous locations	03/03/2024	Remove all vegetation gorse/whin are growing on the crown and sides of the flood relief channel. Currently growing is numerous areas
641	Eil Burn	Behind Burnside Lane	15/12/2023	Remove vegetation along ditch. Priority increased following updated observation of increased weed growth.
651	Dingwall Flood Defences	Sections 3, 4 and 5	07/02/2024	Complete clearance of all vegetation growing in sections 3, 4 and 5 of the flood defences
658	Slackbuie Channel	Junction of Culduthel Road and Green Drive	09/01/2024	Silt accumulations and a build up of debris/rubbish at the culvert, some of which is lying at the twin culvert inlets, please remove as much silt as possible and ensure inlets are clear.
660	Red Burn	Feabuie Road Junction	10/04/2024	Culvert collapsing due to HGV damage, culvert capacity is severely impacted, sidewall is collapsing into the burn, repair roof of the culvert and reinstate burnside ditch 10m downstream from the outlet to allow unrestricted flow.
663	Beechwood Burn	Opposite the Veterinary Centre on the B9006 Culloden Road	10/04/2024	The outlet of structure 60 is suffering silt and vegetation deposition approx 90% surcharged, the inlet of structure 70 has similar issues although not surcharging, deposition is deflecting waterflows towards the sidewall, ditch burn 10 metres downstream from the outlet and 10m upstream from the inlet to return burn to original invert levels.
664	Ault na Skiah	Culvert outlet opposite Evan Barron Rd	10/04/2024	The culvert outlet is 50% surcharged due to windblown trees and woody debris lying across the watercourse for the majority of the open section down to the boundary fence of the property. Clear all woody debris from the open section.
685	Contullich Burn	Contullich Burn, upstream of culvert	19/01/2024	Large tree branch and debris lying near the culvert inlet. A shopping trolley and more debris downstream from the outlet. Debris is to be removed.
690	Ben View Burn	Near Passing Place Lay-by next to Brahan View, Upper Arcan Road Marybank.	08/01/2024	Heavy Vegetation surrounding Inlet & all along Bank Upstream to Structure 60 & Downstream to S72. Vegetation to be cut back 10m Upstream from Inlet of S70 & all along Downstream between S70 & S72.
694	Knockbain Burn	Knockbain Silt Traps, Blackwells Court. Dingwall	08/01/2024	Silt build up across all 3 Screens, particularly in far left & right Screens. Very Large Stone washed down into Screen on LHS facing D/S. All Silt in 3 Screens to be ditched out & removed.
698	Ault na Skiah	Upper Slackbuie, near Electricity Distribution Site, Inverness	10/01/2024	Screen Heavily blocked with large Woody Debris & Leaves all along the entire width, causing large pooling of Water. Screen to be cleared entirely.
700	Tower Burn	Near T-Junction of Caulfield Road North & Murray Road, Smithton.	10/01/2024	Large Stone washed up onto Screen, should be removed to ensure unrestricted flow
702	Tain Burn 2	Within St Vincent Estate	27/04/2024	Section 18 Letter issued to the Homeowners. Heavy Vegetation & Woody Debris within a section of the Watercourse within property boundaries.
703	Miller Road Burn	Miller Road, Cromarty	13/05/2024	Silt build up along Watercourse D/S from Outlet and within Culvert itself. Silt to be removed/ ditched to ensure unrestricted flow.
704	Dores Burn 1	Torr Gardens, Dores	14/05/2024	Vegetation dumped on top of Watercourse, blocking the Culvert Inlet. Needs to be removed.
708	Hill Terrace Burn	Hill Terrace, Kinlochleven	21/02/2024	Wire Fence along Bank collapsed should be repaired to prevent blockages & prevent public falling in.
710	Hill Terrace Burn	Hill Terrace, Kinlochleven	21/02/2024	Silt/ Stone build up near Inlet. Should be removed to ensure unrestricted flow.
714	Slackbuie Spring	Upper Slackbuie along SWFRC, Inverness.	05/03/2024	Vegetation on spill to be cut down to geo fabric underneath.
716	River Peffery Trib1	Along boundary fence of Tulloch Farm, Dingwall. U/S from S100	06/03/2024	Section of Wire Fencing U/S from S100 blocked with Leaves. S18 Letter issued to Landowner to clear Leaves from Fence & cut bottom Wire Link on bottom of Fence to allow Leaves to flow down overspill section unrestricted.

* The stated date for re-inspection denotes when the re-inspection is due and not when the works are due to be carried out