



Notes

- © Crown Copyright and database rights 2023 AC0000849432
- All dimensions are in millimetres unless otherwise stated.
 - The specification referred to in this drawing is the *Specification for Highway Works (SHW)* published by T.S.O. (The Stationery Office).
 - Cover shall comply with BS EN 124 unless otherwise stated. Grating to have a minimum roadway area of 0.125m² and to withstand BS EN 124 test load.
 - Purpose made plastic upper sections with pre-fitted gratings may be used. Plastic upper sections shall be surrounded with ST4 concrete to SHW CI 2602. Dimensions shown for precast slab.
 - Pipe used for shaft shall be precast concrete to BS EN 1916 and BS 5911-1, or PVC-U to BS EN 1401-1.
 - Precast concrete base unit (as shown), 100 thick in situ ST4 concrete base or purpose made plastics base.

Revision Details			
Drawn by	Checked by	Checked by	Surf.
JC	CHK		
Date	Date	Date	
02/2024	03/2024		



Project: Standard details. Series 0500:
 Drainage and service ducts

Title: 600 catchpit chamber

Scale (at A4): Not to scale

Drawn	JC	Date	02/2024
Checked	CHK	Date	03/2024

Drawing No: SD/0500/18

Rev: 1