



Random rubble uncoursed masonry wall  
with stone-on-edge cope

Random rubble uncoursed masonry wall  
with half circle dressed masonry cope

**Notes**

- © Crown Copyright and database rights 2023 AC0000849432
- 1. All dimensions in millimeters unless otherwise stated.
- 2. The stone shall be locally obtained stone and shall be carefully selected to provide a natural and consistent appearance.
- 3. Stones to comply to SHW Clauses 2409 and 2413.
- 4. Stone masonry shall comply with BS5628-3:2002 except if otherwise stated.
- 5. All mortar to comply with SHW Clause 2404.
- 6. Depth from ground level to top of foundation shall be 250mm unless otherwise stated.
- 7. Foundation to be Mix ST5 concrete.

| Revision Details |            |              |        |
|------------------|------------|--------------|--------|
| Drawn by         | Checked by | Checked Date | Surf.x |



Project Standard details, Series 2400:  
Brickwork, blockwork and stonework

Title Random rubble masonry walls

Scale (at A4) Not to scale

|         |     |      |         |
|---------|-----|------|---------|
| Drawn   | JC  | Date | 05/2024 |
| Checked | CHK | Date | 07/2024 |

|             |            |      |   |
|-------------|------------|------|---|
| Drawing No. | SD/2400/02 | Rev. | 1 |
|-------------|------------|------|---|